

T962 MINOS ODH ANALYSIS ANALYSIS

R Sanders

March 04, 2008

(1.0) Introduction

This document presents the T962 LAR TPC Minos Hall ODH analysis.

(2.0) General Information

(2.1) Equipment Failure Rates

FESHM 5064.TA pages 4-5, Table 2, NRC Equipment Failure Rate Estimates

Pfdew = 1e-6**(1/hr) (probability of dewar rupture)

FESHM 5064.TA page 3, Table 1, Fermilab Equipment Failure Rate Estimates

Pfp = 1e-9**(1/hr) (probability of pipe section failure)
Pfv = 1e-8**(1/hr) (probability of valve external leak)
Pfr = 1e-5**(1/hr) (probability of premature opening of relief valve)
Pfw = 3e-9**(1/hr) (probability of weld failure)
Pfg = 3e-7**(1/hr) (probability of gasket failure)
Pfms = 3e-4 (probability of motor failure to start on demand)
Pmoterfail = 1e-5**(1/hr) (probability of running motor failure)
Ppowerout = 1e-4**(1/hr) (probability of a power outage)
Pdieselfail = 3e-2 (probability of diesel plant not starting on demand)

ODH Sensor and Chassis Failure

The oxygen sensors and chassis is an MSA model # A-ULTIMAX3-A0M30000-14-0-3-14-0-2-0000. This unit has two 0-25% range oxygen sensors; One sensor measuring the oxygen concentration in the mixing chamber and one sensor measuring the oxygen concentration 1 foot off the floor below the cryostat. The unit has alarm contacts that will turn on both mixing fans. The ULTIMAX3 performs self diagnostics and has a fail safe set of contacts to indicate a fault.

The ULTIMAX3 has a SIL-2 rating for safety shutdown system as defined by the standard CEIIEC 61611-1 Functional Saety - Safety Instrumented Systems for the process industry sector. In Table 3 of that standard, Its certified reliability for probability of failure upon demand (PFD) is greater than 0.01 but less than 0.001. The probability of failure will be set to the lowest of these two numbers.

Putimafail = 0.01

Fan failure

There would be two mixing fans in parallel that blow air from the upper portions of the Minos Hall. This analysis assumes only one of the fans is operational, the other could be undergoing maintenance. The mixing fans will be on generator backup.

$$\begin{aligned} P_{ffan} &= P_{timafail} + P_{dieselfail} * 1 \text{ hr} * P_{powerout} + P_{fms} \\ P_{ffan} &= 0.10303e-1 \end{aligned}$$

(2.2) Fluid Properties

From Airco Industrial Gases Data Handbook (AGG 1077C), the following data was acquired. Listed are the densities at standard conditions (70 F and 1 ATM) of helium, nitrogen and air. Also there is the density of Liquid nitrogen at 1 ATM and the conversion of gallons of liquid nitrogen to cubic feet of nitrogen gas at standard conditions.

$$\begin{aligned} \text{RhoStdAir} &= 0.07493 \text{ (lb/ft}^3\text{)} && \text{(density of air at standard conditions)} \\ \text{RhoStdAr} &= 0.1034 \text{ (lb/ft}^3\text{)} && \text{(density of argon at standard conditions)} \\ \text{CpAr} &= 0.1244 \text{ (BTU/(lb}^{\circ}\text{R))} && \text{(specific heat of argon gas)} \\ \text{CpAir} &= 0.2406 \text{ (BTU/(lb}^{\circ}\text{R))} && \text{(specific heat of air)} \\ \text{RhoLAr} &= 1.3936 \text{ (lb/L)} && \text{(density of liquid argon at 1 atm)} \end{aligned}$$

density of water

$$\text{rhoH2O} = 62.4 \text{ (lb/ft}^3\text{)}$$

density and viscosity of saturated vapor argon at 1 atm. AIRCO Industrial Gases Data Book

$$\begin{aligned} \text{RhoArVap} &= 0.35976 \text{ (lb/ft}^3\text{)} && \text{(argon vapor density)} \\ \text{MuArVap} &= 72.4e-6 \text{ (gm/(cm}^{\circ}\text{s))} && \text{(argon vapor viscosity)} \end{aligned}$$

From NIST at 2.5 psig, or 17.2 psia, for saturated vapor argon, the density and viscosity are:

$$\begin{aligned} \text{rhoArV25} &= 0.4163 \text{ (lb/ft}^3\text{)} \\ \text{muArV25} &= 4.909e-6 \text{ (lb/(ft}^{\circ}\text{s))} \end{aligned}$$

(2.3) Ventilation Rates

The mixing fans are McMasterCarr Model # 2058K2, page 620 of the McMaster Carr catalog. It is listed as a Medium Duty Flush-Mount Direct-Drive Wall Exhaust Fan with a 10" blade diameter. Its rated capacity is

1060 cfm at 0 inches water column

930 cfm at 1/8 inches water column

860 cfm at 1/4 inches water column

The two mixing fans are attached to the sides of the mixing chamber (also called the bath tub), blowing air into the mixing chamber. The air is drawn from a 12 inch diameter duct drawing air from above the height of

the cryostat. Assume an air flow rate of 860 cfm and show in the following calculations, the pressure drop to be less than 1/4 inch water column.

```
Q = 860**(ft^3/min)      (volumetric flow rate)
Convert(ToSec)Q
Le = 170**in            (duct length)
Convert(ToFt)Le
Le = 14.166666666666**ft
RhoStdAir = 0.07493**(lb/ft^3)      (density of air at standard conditions)
```

From Crane Tech Paper 910, air viscosity

```
mu = 1.2768e-3**(lb/(ft*s))
rho = RhoStdAir
w = Q*rho
```

Duct diameter

```
di = 12**in
Convert(ToFt)di
di = 1.**ft
```

flow area

```
a = di^2*Pi/4
a = 0.7853981634**(ft^2)
```

Determine velocity

```
v = w/(a*rho)      (velocity)
v = 18.2497668078**(ft/s)
Re = di*v*rho/mu    (Reynolds number)
Re = 1071.0017441367
```

Since the flow is laminar ($Re < 2000$) The friction factor is:

```
f = 64/Re
f = 64/1071.0017441367
```

The K factor due to length is:

```
Kle = f*Le/di
Kle = 0.8465594679
```

The K factor for the exit is:

```
Kout = 1.0
```

The total K factor is:

```
Kt = Kle+Kout
Kt = 1.8465594679
```

Find the pressure drop and head loss.

```
dp = Kt*rho*v^2/(2*gc)      (pressure drop)
```

$$dp = 0.7161411296 \cdot (lb/ft^2)$$

The pressure drop in inches water:

$$\begin{aligned} \text{headloss} &= dp / (62.4 \cdot (lb/ft^3) \cdot g/gc) \\ \text{headloss} &= 0.1147662066 \cdot 1 \cdot ft \\ \text{Convert (ToIn) headloss} \\ \text{headloss} &= 0.137719448 \cdot in \end{aligned}$$

The pressure drop is less than 1/4 inch water column. Therefore the flow rate for one mixing fan is:

$$Q_{\text{mixfan}} = 860 \cdot (ft^3/min)$$

Exhaust fan EF-4, located on the surface drawing air through a shaft at the downstream end of the MINOS hall. It provides the normal HVAC ventilation in the MINOS hall and is on generator backup.

$$Q_{\text{ef4}} = 4000 \cdot (ft^3/min)$$

(2.4) Minos Hall Dimensions

From Minos construction Drawing No. 6-7-4 C-57

$$\begin{aligned} H_{\text{mh}} &= 32 \cdot ft && \text{(height of main hall)} \\ L_{\text{mh}} &= 150 \cdot ft && \text{(length of main hall)} \\ W_{\text{mh}} &= 35 \cdot ft + 10 \cdot in && \text{(width of main hall)} \\ W_{\text{mh}} &= \text{Convert (ToFt)} W_{\text{mh}} \\ W_{\text{mh}} &= 35.8333333333 \cdot ft \\ H_{\text{mat}} &= 21 \cdot ft + 6 \cdot in && \text{(height Minos Access Tunnel)} \\ H_{\text{mat}} &= \text{Convert (ToFt)} H_{\text{mat}} \\ H_{\text{mat}} &= 21.5 \cdot ft \end{aligned}$$

The Minos Access Tunnel length.

$$\begin{aligned} L_{\text{mat}} &= 200 \cdot ft && \text{(length of Minos access tunnel)} \\ W_{\text{mat}} &= 21 \cdot ft + 6 \cdot in && \text{(width of Minos access tunnel)} \\ W_{\text{mat}} &= \text{Convert (ToFt)} W_{\text{mat}} \\ W_{\text{mat}} &= 21.5 \cdot ft \end{aligned}$$

Volume of Minos Hall and Minos access tunnel.

$$\begin{aligned} Vol &= H_{\text{mh}} \cdot L_{\text{mh}} \cdot W_{\text{mh}} + H_{\text{mat}} \cdot L_{\text{mat}} \cdot W_{\text{mat}} \\ Vol &= 0.26445e6 \cdot (ft^3) \end{aligned}$$

Volume of lower 8 ft of Minos Hall and Minos access tunnel.

$$\begin{aligned} Vol_{18} &= 8 \cdot ft \cdot (L_{\text{mh}} \cdot W_{\text{mh}} + L_{\text{mat}} \cdot W_{\text{mat}}) \\ Vol_{18} &= 0.774e5 \cdot (ft^3) \end{aligned}$$

Volume of lower 2 ft of Minos Hall and Minos access tunnel.

$$\begin{aligned} Vol_{12} &= 2.0 \cdot ft \cdot (L_{\text{mh}} \cdot W_{\text{mh}} + L_{\text{mat}} \cdot W_{\text{mat}}) \\ Vol_{12} &= 0.1935e5 \cdot (ft^3) \end{aligned}$$

(2.5) Cryostat Data

Dimensions and volume of cryostat

```
InnerOD = 30**in      (outside diameter of inner vessel)
Convert(ToFt)InnerOD
InnerOD = 2.5**ft
```

Inner vessel wall. PHPK 07-2032-BM-6501C, item 3

```
InnerWall = (3/16)**in
```

From PHPK DRW # 07-2032-6501, SHEET 2 of :

```
InnerL = (49+15/16)**in      (overall length of inner vessel)
InnerL = 49.9375**in
Convert(ToFt)InnerL
InnerL = 4.1614583333**ft
```

Use a Conservative formula to calculate the liquid argon volume.

```
VLar = InnerL*Pi*InnerOD^2/4
VLar = 0.2042751082e2** (ft^3)
Convert(ToLiter)VLar
VLar = 0.5784427599e3**L
```

By itself a single 160L liquid argon dewar used in filling the main dewar, has a liquid volume of:

```
M160 = V160*RhoLAr      (mass of 160L liquid argon dewar)
M160 = 0.222976e3**1b
Q160 = M160/RhoStdAr    (160 L dewar, cubic feet of argon)
Q160 = 2156.4410058027** (ft^3)
```

At the end of filling operations, there could still be a partial 160 L portable dewar left in the Minos Hall.

Assume a full 160 L dewar connected to a full 500L stationary dewar.

```
TVLAr = 0.7384427599e3**L      (total volume of liquid argon)
TMAr = TVLAr*RhoLAr      (total mass of argon)
TMAr = 0.102909383e4**1b
TQAr = TMAr/RhoStdAr     (total standard cubic feet of argon)
TQAr = 9952.551549486** (ft^3)
```

(2.6) Cryogenic System Data

The Flow schematic 9219.000-MD-444703 27 valves on the system that come in contact with argon in the Minos Hall. Assume a larger number so that this analysis remains valid even if small changes are made to the system.

```
NumArV = 40      (number of argon valves)
```

FESHM 5064 lists failure rates of piping as per section of pipe. Generally pipes come in 20 ft sections. Assume 100 ft of pipe and tubing.

```
SecArPipe = 5      (sections of argon piping)
```

The number of relief valves that vent into the MINOS hall.

NumArRV = 0 (number of argon relief valves)

Number of welds on the argon piping system.

NumArWelds = 150 (number of welds on argon piping)

There will be one traditional piping gaskets on the system. But there will be a number of connections with metal to metal seals or orings. The probability of failure for gaskets, listed in FESHM 5064, for these connections.

NumArGasket = 12 (number of joints with seals)

(2.7) Depressurizing The Dewar After Piping Failure

Assume the dewar is full of liquid and under 3 bar pressure and there is a sudden cryogenic system piping failure causing the dewar to rapidly depressurize and vent argon into the MINOS hall. Determine the mass fraction of that is vaporized and vented into the MINOS hall.

Argon Properties

The internal energy and density of the liquid in the dewar at 3 bar before the piping failure is:

$u_{L3} = 82.2382$ (J/gm)
 $\rho_{L3} = 1.349$ (gm/cm³)

After the piping failure the enthalpy of the vapor leaving the cryostat at the average pressure of 2 bar is:

$h_{V2} = 238.2252$ (J/gm)

After the dewar is depressurized, the liquid and vapor properties at 1 bar is:

$u_{L1} = 73.677$ (J/gm)
 $u_{V1} = 218.3639$ (J/gm)
 $\rho_{L1} = 1.393$ (gm/cm³)
 $\rho_{V1} = 0.005705$ (gm/cm³)

Calculate Volume Fraction

In the following formula, y is the volume fraction of the dewar that is vapor after the dewar is depressurized from 3 bar to 1 bar. This formula was derived from an energy and mass balance on the dewar volume. The derivation assumed the enthalpy of the vapor departing the dewar is the saturated vapor enthalpy at 2 bar. It will be shown that this formula satisfies a mass balance and energy balance equations on the the control dewar.

$y = (\rho_{L3} * u_{L3} - \rho_{L1} * u_{L1} - \rho_{L3} * h_{V2} + \rho_{L1} * h_{V2}) / (\rho_{V1} * u_{V1} - \rho_{L1} * u_{L1} - \rho_{V1} * h_{V2} + \rho_{L1} * h_{V2})$
 $y = 0.820121702e-1$

Mass Balance

The control volume in these calculations is the original volume of the liquid in the dewar.

```
Vdew = VLar
Vdew = 0.5784427599e3**L
Convert ({L<-cm^3})Vdew
Vdew = 0.5784427599e3**(cm^3)
```

The Total mass in the dewar when it is 100% liquid at 3 bar.

```
Mtotal = rhoL3*Vdew
Mtotal = 0.7803192831e3**gm
```

Mass of vapor argon remaining in the dewar when it is at 1 bar, after vapor has vented from the dewar.

```
MV1 = y*rhoV1*Vdew
MV1 = 0.2706414693**gm
```

Mass of liquid argon remaining in the dewar when it is at 1 bar, after vapor has vented from the dewar.

```
ML1 = (1-y)*rhoL1*Vdew
ML1 = 0.7396877554e3**gm
```

Mass of argon remaining in the dewar when it is at 1 bar.

```
M1 = ML1+MV1
M1 = 0.7399583969e3**gm
```

Mass of argon vapor exiting the dewar into the MINOS Hall.

```
Me = Mtotal-M1
Me = 0.4036088618e2**gm
```

Perform a mass balance on the dewar. Mass that was in the dewar before it was depressurized should equal the mass left in the dewar afterward plus the mass that exits the dewar.

```
Mtotal==M1+Me
0.7803192831e3**gm==0.7803192831e3**gm
```

The Mass baance is satisfied.

Energy Balance

The Total energy in the dewar, in the before state, when it is 100% liquid at 3 bar.

```
Ettotal = Mtotal*uL3
Ettotal = 0.6417205327e5**J
```

Energy of argon vapor exiting the dewar into the MINOS Hall.

```
Ee = Me*hV2
Ee = 0.9614980182e4**J
```

Energy left in dewar after it is depressurized.

```
E1 = MV1*uV1+ML1*uL1
E1 = 0.5455707308e5**J
```

Energy balance

```
Ettotal==E1+Ee
0.6417205327e5**J==0.6417205327e5**J
```

The energy balance is satisfied. The equations used above to determine the mass of argon vaporized when depressurizing are correct. The mass fraction of the total argon that is vented.

```
Mfraction = (Mtotal-M1)/Mtotal
Mfraction = 0.5172355349e-1
```

(3.0) Preliminary Calculations

(3.1) Complete Mixing in Minos Hall and Minos Access Tunnel

Assume the entire inventory of argon is released into the hall and mixed. Only pure air out of the hall is displaced to make room for the argon. Subtract total standard cubic feet of argon TQAr (section 2.5) from the combined volume of the Minos Hall and Minos access tunnel, Vol (section 2.4).

```
Qair = Vol-TQAr      (standard cubic feet of air)
Qair = 0.2544974484e6**(ft^3)
ocr = 0.21*Qair/Vol  (oxygen concentration)
ocr = 0.2020966692
```

Fatality factor:

```
FatalityFactor(ocr) = 0.0**fatalities
```

The above calculation assumed all of the argon is spilled and stays in the hall and access tunnel, there is complete mixing and no fresh air enters. The resulting oxygen concentration is over 18% and the fatality rate is 0. The implication is that there is sufficient air in the Minos hall and access tunnel for mixing with argon to achieve a fatality factor of 0. Fresh air does not need to be brought in from the surface.

(3.2) Mixing in the Bottom 8 ft of the Minos Hall and Minos Access Tunnel

Assume the entire inventory of argon is released and mixed. Only pure air is displaced to make room for the argon. Subtract total standard cubic feet of argon TQAr (section 2.5) from the volume of bottom 8 ft of the Minos Hall and Minos access tunnel, Vol8 (section 2.4).

```
Qair = Vol8-TQAr      (standard cubic feet of air)
Qair = 0.6744744845e5**(ft^3)
ocr = 0.21*Qair/Vol8  (oxygen concentration)
ocr = 0.1829969531
```

Fatality factor:

$$\text{FatalityFactor}(\text{ocr}) = 0.0 \times \text{fatalities}$$

The resulting oxygen concentration is over 18% and the fatality rate is 0. Complete mixing in the entire cavern is not required. Furthermore, in the worst possible possible ODH disaster, a person is completely safe by going up the stairs to the catwalk around the MINOS detector.

(3.3) Mixing in the Bottom 2 ft of the Minos Hall and Minos Access Tunnel

Assume the entire inventory of argon is released and mixed. Only pure air is displaced to make room for the argon. Subtract total standard cubic feet of argon TQAr (section 2.5) from the volume of bottom 2 ft of the Minos Hall and Minos access tunnel, Vol2 (section 2.4).

$$\begin{aligned} Q_{\text{air}} &= \text{Vol2} - \text{TQAr} && \text{(standard cubic feet of air)} \\ Q_{\text{air}} &= 9397.4484505138 \times (\text{ft}^3) \\ \text{ocr} &= 0.21 \times Q_{\text{air}} / \text{Vol2} && \text{(oxygen concentration)} \\ \text{ocr} &= 0.1019878126 \end{aligned}$$

Fatality factor:

$$\text{FatalityFactor}(\text{ocr}) = 0.7094373544 \times 10^{-1} \times \text{fatalities}$$

The resulting oxygen concentration is less than 11% and the fatality rate is about 10%. With less mixing the fatality rate would be 1.0. If there were a large argon release with little or no mixing, people working at the floor level or someone who falls down onto the floor would be at great risk. In this analysis, any unmixed argon releases will be assigned a Fatality factor of 1.0.

(3.4) After Piping Failure, Mixing in the Bottom 2 ft of the Minos Hall and Minos Access Tunnel

Assume the cryogenic piping system fails causing the dewar to depressurize. As discussed in section 2.7, only a small fraction of the dewar contents will be vented due to the depressurizing process. Assume this vent rate, for a short time overwews the mixing system. Determone the fatality factor in the bottom 2 fet.

$$\begin{aligned} Q_{\text{air}} &= \text{Vol2} - \text{Mfraction} \times \text{TQAr} && \text{(standard cubic feet of air)} \\ Q_{\text{air}} &= 0.1883521866 \times 10^5 \times (\text{ft}^3) \\ \text{ocr} &= 0.21 \times Q_{\text{air}} / \text{Vol2} && \text{(oxygen concentration)} \\ \text{ocr} &= 0.2044132258 \end{aligned}$$

Fatality factor:

$$\text{FatalityFactor}(\text{ocr}) = 0.0 \times \text{fatalities}$$

There is no ODH problem for the initial release from a piping failure.

(3.5) Complete Mixing of 160L Dewar in the Bottom 2 ft of the Minos Hall and Minos Access Tunnel

Assume the entire content of argon in the 10L dewar is released and mixed into the bottom two feet of the Minos Hall. Only pure air is displaced to make room for the argon.

```
Qair = Vol2-Q160      (standard cubic feet of air)
Qair = 0.1719355899e5**(ft^3)
ocr = 0.21*Qair/Vol2  (oxygen concentration)
ocr = 0.1865967642
```

The fatality factor of spilling a 160 L dewar into the MINOS hall.

```
FF160 = 0.0**fatalities
```

The resulting oxygen concentration is greater than 18% and the fatality rate is about 0%. The consequence of a 160L dewar spill by itself does not affect the ODH classification of the MINOS hall.

(3.6) Normal Boil Off From Dewar

There is a 350 W electric heater inside the cryostat. The heat load on the cryostat is expected to be 100W. The Cryocooler that cools the cryostat has only a 350W capacity. Determine the sustained boiloff from the dewar if there is a piping leak. Assume there is a large leak o the piping above the cryostat. Assume for instance, the top 18 inch flange on the cryostat is unbolted or a 1/2 inch cryogenic line is severed into two pieces. Section 3.5 above, shows that the initial pressurization of the dewar would at most boil off less than 6% of the argon liquid. What is the maximum sustained boil off from the cryostat after such an accident.

Assume the cryostat is venting into the MINOS hall. Assume tat liquid argon in the cryostat is at 14.7 psia and the heater is at full power. Assume the external heat load on the cryostat is twice the expected 100W. The normal heat load Q_n , on the cryostat would then be:

```
Qn = 350**W+2*100**W
Qn = 550**W
```

For saturated vapor argon at 14.7 psia, the enthalpy is:

```
hg = 43.6193** (J/gm)
```

For saturated liquid argon at 14.7 psia, the enthalpy is:

```
hf = (-0.117517e3)** (J/gm)
```

The release rate from the dewar open to the atmosphere in MINOS hall is:

```
RRn = Qn/((hg-hf)*RhoStdAr)
RRn = 33.0102462087**((W*gm*ft^3)/(lb*J))
Convert({ToLb,ToJS,ToMin})RRn
RRn = 4.3665078438** (ft^3/min)
```

(3.7) MINOS Hall EF4 Ventilation

The number of air changes per hour in the Minos Hall and access tunnel due to the HVAC ventilation fan

EF4 is

```
AirChng = Vol/Qef4
AirChng = 66.1125**min
Convert (ToHr)AirChng
AirChng = 1.101875**hr
```

The average velocity of the air flow in the MINOS hall due to EF4 is equal to the fan capacity divided by the cross sectional area of the Minos Hall:

```
Vef4 = Qef4/(Hmh*Wmh)
Vef4 = 3.488372093** (ft/min)
```

The flow rate of air in the bottom 2 feet of the MINOS hall is:

```
Q2ef4 = 2.0**ft*Wmh*Vef4
Q2ef4 = 250.** (ft^3/min)
```

The oxygen concentration is:

```
Crn = 21*(Q2ef4-RRn)/Q2ef4
Crn = 20.6332133411
```

Two important conclusions can be drawn from this result. The ventilation provided by EF4 is sufficient to remove ODH problems caused by leakage from the cryogenic piping system. The operation of the EF4 fan is capable of dealing with all ODH problems except failure of the Cryostat internal vessel. This analysis takes no credit for the ventilation provided by EF4. However is is on generator backup and its continuous operation does significantly reduce the ODH risk.

The second conclusion is, if a large, sudden argon spill occurs, the ventilation provided by EF4 will over time establish a 21% oxygen concentration in the MINOS hall.

(3.8) Release Rate From Dewar Inner Vessel Failure

Assume the dewar inner vessel fails. The vacuum jacket will fill with argon and its relief valve will open venting to the surface. Detrmine the leak rate rate out of the vacumm jacket flanges into MINOS hall.

End Flange

This assumes an internal dewar leak

Flange dimensions are below. PHPK 07-2032-BM-6502C, item 15

```
flangeid = 41.5**in
flangeod = 48.0**in
```

Machining tolerances are on PHPK drawing 07-3032-6502 sheet 4.0

```
gap = 0.010**in
wd = Pi*(flangeid+flangeod)/2 (average width of the flow path)
```

```

wd = 0.1405862712e3**in
a = wd*gap
a = 0.0140586271e2**(in^2)
Le = (flangeod-flangeid)/2
Le = 3.25**in

```

The pressure drop across the flange is the internal pressure rating of vacuum jacket.

```
dp = 5**psi
```

fluid properties, use the average pressure in the flow path.

```

rho = rhoArV25      (density)
rho = 0.4163**(lb/ft^3)
mu = muArV25      (viscosity)
mu = 4.909e-6**(lb/(ft*s))

```

Hydraulic diameter is 4 times the flow area divided by the perimeter of the flow path.

```

dh = 4*a/(2*wd)
dh = 0.2e-1**in

```

Assume f

```
f = 0.0411      (assume a friction factor)
```

input K factors

```

Kin = 0.5
Kout = 1.0
Kl = f*Le/dh
Kl = 6.67875
Ktotal = Kin+Kl+Kout      (total K factor)
Ktotal = 8.1787499999

```

Calculate Velocity

```

v = ((dp*2*gc)/(Ktotal*rho))^0.5      (velocity)
v = 9.7208861474**((psi^0.5*ft^2.)/(lbft^0.5*s))
v = Convert({{psi<-1*lbft/in^2}},ToFt)}v
v = 116.6506337687**ft/s

```

Confirm that correct friction actor was used. The Reynolds number is:

```

Re = dh*v*rho/mu      (Reynolds number)
Re = 0.1978474591e6**in/ft
Re = Convert({ToFt,ToSec,ToLb})Re
Re = 0.1648728825e5
epsilon = epsilon      (pipe roughness)
f = FrictionFactor3(Re,epsilon,id)      (confirm assumed friction factor)
f = FrictionFactor3(0.1648728825e5,0.00015**ft,id)

```

outputs

```

w = a*v*rho      (mass flow)
w = 0.6827102541e2**((lb*in^2)/(ft^2*s))

```

Mass flow rate through end flange

```
wef = Convert(ToFt)w
wef = 0.4741043431**(lb/s)
```

(3.9) Case 3, Piping Component Failure

This consist of failures of piping components such as argon valves. Pfpipeline , section 4.4

The release rate RRpipe ; see section 3.2.

```
W3 = 224**(lb/hr)
RR3 = W3/RhoStdAr      (case 3 release rate)
RR3 = 2166.3442940039**(ft^3/hr)
Convert(ToMin)RR3
RR3 = 36.1057382334**(ft^3/min)
```

Side Flange

Flange dimensions are below. PHPK 07-2032-BM-6502C, items 20 and 25

```
flangeid = 14.0**in
flangeod = 18.0**in
wd = Pi*(flangeid+flangeod)/2      (average width of the flow path)
wd = 0.5026548245e2**in
a = wd*gap
a = 0.0502654824e1**(in^2)
Le = (flangeod-flangeid)/2
Le = 2.**in
```

Hydraulic diameter is 4 times the flow area divided by the perimeter of the flow path.

```
dh = 4*a/(2*wd)
dh = 0.2e-1**in
```

Assume f

```
f = 0.0411      (assume a friction factor)
```

input K factors

```
Kin = 0.5
Kout = 1.0
Kl = f*Le/dh
Kl = 4.11
Ktotal = Kin+Kl+Kout      (total K factor)
Ktotal = 5.6100000001
```

Calculate Velocity

```
v = ((dp*2*gc)/(Ktotal*rho))^0.5      (velocity)
v = 11.7372915563**((psi^0.5*ft^2.)/(lbf^0.5*s))
v = Convert({{psi<-1*lbf/in^2},ToFt})v
v = 140.8474986762**(ft/s)
```

Confirm that correct friction actor was used. The Reynolds number is:

```
Re = dh*v*rho/mu      (Reynolds number)
```

```

Re = 0.2388869981e6**(in/ft)
Re = Convert({ToFt,ToSec,ToLb})Re
Re = 0.1990724984e5
epsilon = epsilon      (pipe roughness)
f = FrictionFactor3(Re,epsilon,id)      (confirm assumed friction factor)
f = FrictionFactor3(0.1990724984e5,0.00015**ft,id)

```

outputs

```

w = a*v*rho      (mass flow)
w = 0.2947307199e2**((lb*in^2)/(ft^2*s))

```

Mass flow rate through side flange

```

wsf = Convert(ToFt)w
wsf = 0.204674111** (lb/s)

```

Combined mass flow rate through flanges.

```

wf = wef+wsf
wf = 0.6787784542** (lb/s)
RRvflange = wf/RhoStdAr      (volumetric flow at standard conditions)
RRvflange = 6.5645885322** (ft^3/s)
RRvflange = Convert(ToMin)RRvflange
RRvflange = 393.8753119367** (ft^3/min)

```

(3.9) Case 3, Simultaneous Piping Failure and Loss of Vacuum

From the dewar engineering note, the mass flow rate in the vent system for a loss of vacuum is:

```

W3 = 224** (lb/hr)

```

If there were a piping failure at the same time, the release rate into the hall would be:

```

RR3 = W3/RhoStdAr      (case 3 release rate)
RR3 = 2166.3442940039** (ft^3/hr)
Convert(ToMin)RR3
RR3 = 36.1057382334** (ft^3/min)

```

(4.0) Probability of Events That Cause Large Argon Releases

(4.1) (Case 1) Dewar Inner Vessel Failure

This dewar is unusual in that the inner vessel is not entirely welded; it has a large internal flange with a metal seal. The probability of a failure of the inner vessel will be then be the normal dewar failure rate used at Fermilab plus a gasket failure rate to account for the possibility of the flange seal leaking.

```

Pr1 = Pfdew+2*Pfg      (case probability)
Pr1 = 0.16e-5** (1/hr)

```

(4.2) (Case 2) Simultaneous Inner vessel and Vacuum Vessel Failure

This is the probability of an inner vessel failure from case 1 times the probability of a vacuum vessel failure. The vacuum vessel failure rate is assumed to be the same as a dewar.

```
Pr2 = Pfdew*1**hr*(Pfdew+2*Pfg)      (case probability)
Pr2 = 0.16e-11**(1/hr)
```

(4.3) Case 3, Probability of Failed Argon Piping

This consist of failures of piping components such as argon valves. Pfpipeline , section 4.4

```
Pr3 = Pfp*SecArPipe+Pfv*NumArV+Pfw*NumArWelds+Pfg*NumArGasket      (case 3 probability)
Pr3 = 0.4455e-5**(1/hr)
```

(5.0) Calculate ODH Classification

Look at four different cases.

(5.1) Case 1 Dewar Internal Vessel Failure

The dewar inner vessel fails and argon leaks from the vacuum jacket flanges.

```
ocr = 0.21*Qmixfan/(Qmixfan+RRvflange)      (O2 concentration with fan)
ocr = 0.1440334603
FFfan = FatalityFactor(ocr)      (fatality rate with fan)
FFfan = 0.4982995274e-4**fatalities
FFnofan = 1.0**fatalities      (fatality factor with no fan)
Phi1 = Pr1*((1-Pffan)*FFfan+Pffan*FFnofan)
Phi1 = 0.1656370648e-7**(fatalities/hr)
```

(5.2) Case 2 Simultaneous Cryostat Vacuum Vessel and Inner Vessel Failure

Assume a fatality factor of 1.0 for this rare event :

```
FF = 1.0**fatalities
Phi2 = Pr2*FF
Phi2 = 0.16e-11**(fatalities/hr)
```

(5.3) Case 3, Piping Component Failure

assume a simultaneous loss of vacuum. Use the release rate calculated in section 3.10

```
ocr = 0.21*Qmixfan/(Qmixfan+RR3)      (O2 concentration with fan)
ocr = 0.2015387161
FFfan = FatalityFactor(ocr)      (fatality rate with fan)
FFfan = 0.0**fatalities
FFnofan = 1.0**fatalities      (fatality factor with no fan)
Phi3 = Pr3*((1-Pffan)*FFfan+Pffan*FFnofan)
Phi3 = 0.45899865e-7**(fatalities/hr)
```

(5.4) Case IV, Spilling 160 L Dewar

The fatality factor for spilling a 160 L dewar in the MINOS hall during filling operations is 0. Set the fatality rate equal to the fatality factor;

```
Phi4 = FF160/1**hr  
Phi4 = 0**(fatalities/hr)
```

(5.5) ODH Classification

```
Phitotal = Phi1+Phi2+Phi3+Phi4  
Phitotal = 0.6246517148e-7**(fatalities/hr)  
ODHclassification(Phitotal) = ODH Class 0
```

The MINOS hall and Access tunnel has an ODH 0 classification.