

From: Walter Jaskierny <waltj@fnal.gov>
Subject: **Re: smoke alarm test**
Date: April 7, 2009 3:27:36 PM CDT
To: Mitchell Soderberg <mitchell.soderberg@yale.edu>

Hello Mitch,

i have tested the rack protection system on the two relay racks on the upper level. The AC trips off on the AC controllers in both racks if either smoke detector is sprayed with the canned smoke. I have the canned smoke at the Proton Pole Building.

Walt

Hi Walt -

Thanks. The sooner we can test things, the better.

Mitch

On Apr 7, 2009, at 12:53 PM, Walter Jaskierny wrote:

Hello Mitch,

I will see what I can do to find a can of smoke for the test. Early this morning I mentioned to Dwight Featherston that I needed to test the rack protection for you.

Walt

Hi Walt -

Any ideas where I could pick up a can of smoke to test the alarms that you installed in our racks?

Thanks,

Mitch